

**TAMPA BAY WATER – WATER QUALITY ANALYTES  
REGIONAL TO PINELLAS COUNTY**

<b>Analyte</b>	<b>Units</b>	<b>Standards</b>
pH	pH Units	>=7
Conductivity	umhos/cm	<850
Temperature	oC	<35
Total Sulfide	mg/L	<0.1
Alkalinity	mg/L	>100
Total Hardness	mg/L	>300
Calcium Hardness	mg/L	>50
Turbidity	NTU	<1
Color	Apparent C.U.	<15
Ammonia	mg/L	<1
Nitrate	mg/L	<10
Nitrite	mg/L	<1
Fluoride	mg/L	<=0.8
Ortho P	mg/L	<1
Total Dissolved Solids	mg/L	<500
Total Organic Carbon	mg/l	<=4.6
Iron	mg/L	<=0.3
Boron	mg/L	
Dissolved Oxygen	mg/L	
Bromide	mg/L	
Sulfate	mg/L	
Chloride	mg/L	
Bromate	mg/L	
HAAS	ug/L	
TTHM	ug/L	