

BUILDING A WORLD OF DIFFERENCE

PINELLAS COUNTY WATER SYSTEM ENERGY USE AND EFFICIENCY ASSESSMENT



BLACK & VEATCH
Building a world of difference.®

AGENDA

- **Background and Scope**
- **Commercial Power Rate Structures**
- **Energy Use Baseline**
- **Distribution System Efficiency**
- **Renewable Energy Potential**
- **Conclusions and Recommendations**

PROJECT BACKGROUND AND SCOPE

- The 7 primary energy consuming facilities in the Pinellas water distribution system:
 1. S.K. Keller WTP
 2. Regional Treatment Facility
 3. North Water Booster Station
 4. Logan WBS
 5. Oakhurst WBS
 6. Capri WBS
 7. Gulf Beach WBS
- Review current Duke Energy rate schedules
- Evaluate energy use and efficiency of the facilities
- Identify potential to generate renewable energy

COMMERCIAL POWER RATE STRUCTURE ASSESSMENT

- Reviewed current Duke Energy Rate Schedules:
 - General Service - Time of Use (GSDT-1)
 - Interruptible Service - Time of Use (IST-2)
- All facilities on GSDT-1 except Keller (IST-2)



FACILITY	AVERAGE COST OF POWER (\$/KWH)
S. K. Keller Water Treatment Plant	\$0.066
Regional Treatment Facility	\$0.086
North Water Booster Station	\$0.099
Logan Water Booster Station	\$0.092
Oakhurst Booster Station	\$0.091
Capri Water Booster Station	\$0.122
Gulf Beach Water Booster Station	\$0.116

- Opportunity for North WBS to use IST-2
 - Potential savings of 20% / \$90,000 annually
 - Risks of interruptible service must be considered


ENERGY USE BASELINE

- Comprehensive breakdown of current energy use, efficiency and cost at each facility by major equipment
- Supports identification of potential energy efficiency improvements
- Serves as baseline to measure future improvements against

System/Equipment (# of units)	Motor Size (HP) for Each Pump	Motor Efficiency (%)	Drive (Constant Speed or VFD)	Est. Avg. Operating Pump Efficiency (%)	Typical Operation Pumps (No.)	Average Operating Hours			Estimated Energy Demand (kW)		Estimated Energy Usage (kWh)		Estimated Annual Energy Cost (\$)	Actual 2014 Energy Use (kWh)	Actual 2014 Energy Costs (\$)
						Hrs/Dy	Hrs/Mo	Hrs/Yr	Avg	Peak	Monthly	Annual			
580 BPS													\$0.0948	4,303,800	\$397,445
Booster pumps (3 pumps)	500	92%	VFD	80%	2	16	487	5,841	259	598	125,844	1,510,128	\$143,160		
Repump pumps (2 pumps)	800	94%	VFD	80%	1	12	365	4,380	410	578	149,559	1,794,712	\$170,139		
Tank mixers (4 mixers)	--	--	--	--	--	24	730	8,761	1	1	1,008	12,090	\$1,146		
Building and Site Lighting and miscellaneous loads	--	--	--	--	--	24	730	8,761	74	148	54,026	648,311	\$61,460		
Total for 580 BPS						24	730	8,761	744	1,326	330,437	3,965,241	\$375,905	0	\$0
Logan BPS													\$0.0869	1,641,000	\$142,526
Booster pumps (4 future VFD pumps)	250	92%	VFD	80%	1	24	730	8,761	154	308	112,361	1,348,329	\$117,170		
Chlorine booster pump	3	--	CS	--	--	24	730	8,761	2	2	1,392	16,704	\$1,452		
Tank mixers (2 mixers)	--	--	--	--	--	24	730	8,761	1	1	504	6,045	\$525		
Building and Site Lighting and miscellaneous loads	--	--	--	--	--	24	730	8,761	17	34	12,411	148,936	\$12,943		
Total for Logan BPS						24	730	8,761	173	344	126,668	1,520,014	\$132,089	0	\$0
Capri BPS													\$0.1132	325,520	\$36,862
75 HP Booster pumps (2 pumps)	75	90%	CS	65%	1	8	243	2,920	62	125	15,204	182,453	\$20,654		
50 HP Booster pump (1 pump)	50	90%	CS	65%	1	5	152	1,825	43	43	6,479	77,750	\$8,801		
Chlorine booster pump	3	--	CS	--	--	24	730	8,761	2	2	1,392	16,704	\$1,891		
Tank mixers (1 mixer)	--	--	--	--	--	24	730	8,761	0	0	252	3,023	\$342		
Building and Site Lighting and miscellaneous loads	--	--	--	--	--	24	730	8,761	12	24	8,761	105,132	\$11,901		
Total for Capri BPS						24	730	8,761	119	194	32,088	385,060	\$43,589	0	\$0

HISTORIC AND CURRENT ENERGY USE

- **Energy use trended up between 2000 – 2012.**
(Likely due to system operational changes required to improve water quality, fire flow, etc)
- **20% reduction in power consumption for every million gallons produced (kWh/MG) from FY13 to FY15.**
(County's investment in water facility improvements have supported optimized operation of the water system)



ENERGY EFFICIENCY ASSESSMENT

- **Keller WTP:**

- Significant efficiency improvement from 2015 project
- Limited opportunity for additional efficiency improvements



- **Regional Treatment Facility:**

- Limited energy use / Limited opportunities for improvement

- **North WBS:**

- Energy use anticipated to continue a slight downward trend from recent improvements



- **Logan WBS:**

- Significant energy reduction anticipated after current construction project is complete

ENERGY EFFICIENCY ASSESSMENT

- **Oakhurst WBS:**
 - Offline / to be decommissioned
- **Capri WBS:**
 - Current pump sizing is inefficient
 - New pumps and motors would support reduced energy use
- **Gulf Beach WBS:**
 - Current pump sizing is okay
 - Addition of VFD would support reduced energy use
- **Overall Distribution System:**
 - Potential for additional optimization of operating strategies to reduce energy use



RENEWABLE ENERGY POTENTIAL - SOLAR

- **Three Solar PV installation options:**
 - Ground array in open area
 - Roof/tank mounted array
 - Covered parking structure
- **Solar PV ground array at Keller WTP:**
 - Cost = \$1M.
 - Payback = ~39 years (based on \$0.07/kWh)
 - Produces 370,000kWh/yr (6% of use)
- **Solar roof/tank mounted array at North WBS: \$320,000**
 - Cost = \$320,000
 - Payback = ~27 years (based on \$0.10/kWh)



Payback period could be reduced by obtaining grants, increases in energy costs, or decreases in solar PV costs.

RENEWABLE ENERGY POTENTIAL - OTHERS

- **Wind Turbine Energy Generation**

- Average wind speed in Pinellas is lower than typical minimum threshold for considering wind turbines
- Anticipated public concerns with turbines at facility sites (noise, visual intrusion)



- **In-conduit Hydropower Energy Generation**

- Opportunities at locations where control valves are used to reduce pressure:
 - Madeira PRV
 - Fill valves at ground storage tanks.
- Very low potential due to significant daily variations in flows and pressure at control valve locations



CONCLUSIONS AND RECOMMENDATIONS

- 20% improvements in energy efficiency achieved between 2013 to 2015
- Current North WBS and Logan WBS improvement projects are anticipated to further reduce energy use.
- **Opportunities for additional improvements:**
 - New Capri WBS pumps and motors
 - Addition of VFD for Gulf Beach WBS pump
 - Energy optimization modeling to define optimized operating strategies for water distribution system
 - Addition of real time energy use and efficiency tracking on operator screens and management dashboards
 - Interruptible service rate structure at North WBS

CONSISTENCY WITH PINELLAS COUNTY'S STRATEGIC PLAN

- 5.2** - Be responsible stewards of the public's resources
- 5.3** – Ensure effective and efficient delivery of county services
- 3.1** - Implement green technologies and practices where practical
- 3.3** – Protect and improve the quality of our water, air and other natural resources
- 3.4** – Reduce/reuse/recycle resources including energy, water and solid waste

Building a **world** of difference.®

Together



BLACK & VEATCH

www.bv.com

